



TEAM: DEC 1702A

ALGONA DISTRIBUTION SYSTEM DESIGN

CLIENT: ALGONA MUNICIPAL UTILITY
 ADVISOR: KIMBER ANNER
 YUXUAN YUAN, SHENGXIN MAO, CHANGLIN LI

INTRODUCTION

- Iowa
 - Midwestern U.S. state
- Algona
 - A growing city of 5560 people.
 - Location in the north of Iowa
 - Algona Municipal Utilities
- Industrial Consumer Electric Geographic Information System (GIS) Map
 - Second largest Industrial Consumer
 - Primary Feeder EB 5 - Green Line
 - Secondary Feeder 1 - Pink line
 - Old conductor and vegetation problem
 - Two transformers and meters




Figure 1 Iowa google map




Figure 2 Algona google map



Figure 3 Industrial Consumer GIS Map

CURRENT DATA

- North meter average daily Power Factor
 - 0.832
- South meter average daily Power Factor
 - 0.89




Figure 3 Two meter daily PF




Figure 4 Two meter 2016 KW consumption

- North meter 2016 load
 - Max 1196.8 KW
 - 8 outages events
 - Total 15 hours
- South meter 2016 load
 - Max 1395.2 KW
 - 17 outages events
 - Total 35 hours

POWER DISTRIBUTION SYSTEM

- The final state of delivery of electric power
- Directly carry electricity from upper level system to individual consumers




Figure 5 Brief power system process

SIMULATION DETAIL



Figure 11 Milsoft Utility Solutions



Figure 12 DGR Engineering

Milsoft

- provides more than a thousand electric utilities
- #### DGR Engineering
- DeWid Grant Reckert

Origin Modell information:

- Operational
 - Primary Feeder EB5 normal Close
 - Feeder 1 normal Open
- Transformer 2000KVA and 1500KVA




Figure 13 Original Milsoft Model

Model I(AMI Data):

- Operational
 - Feeder EB5 normal Closed
 - Primary Feeder 1 normal Closed
- Transformer 4200 KVA and 1500KVA.
- Feeder 1: 350AL 220 EPR 1/3-90.
 - Capacity 408A
- EB5: 4/0AL 220 EPR 1/3-90.
 - Capacity 326A




Figure 14 Model I

Model II(DGR model data):

- Operational
 - Feeder EB5 normal Close
 - Primary Feeder 1 normal Open
- Transformer 4000 KVA and 1500KVA.
- Feeder 1: 4/0AL 220 EPR FUL 105.
 - Capacity 350A
- EB5: 4/0AL 220 EPR 1/3-90.
 - Capacity 326A




Figure 15 Model II

TRANSFORMER

United States Department of Agriculture Rural Utility Service (RUS) as the construction standards of pad mounted transformer.

Pad Mounted Transformer:

- Around \$17/KVA
- 4200 KVA
 - Around total \$71,400
- 4000 KVA
 - Around total \$68,000
- 1500 KVA
 - Around total \$25,500

Other Parameter Data:

- Three Phase
- 60 HZ
- Percentage of Impedance: 5%-7%
- Cooling type: OA/FA (Oil-Immersed, forced cool)




Figure 6 Pad Mounted Transformer Specifications



Figure 7 Pad Mounted Transformer



Figure 8 ABB Inc.

FEEDER TYPE

United States Department of Agriculture Rural Utility Service (RUS) as the construction standards of Underground and Overhead riser.




Figure 9 Cable riser

Advantage of Underground cable:

- Low Transmission loss
- Absorb Emergency power loads
- Less Susceptible to the impacts of severe weather
- Less Maintenance Cost




Figure 10 Cable riser Specifications

CABLE TYPE




Figure 16 15 kv distribution Underground Cable

- 15KV
- Underground
- Distribution Cable
- Okonite Production



Figure 17 WESCO Distribution Inc.

Cable Type Data:

- 4/0, 220 mils, Al, EPR, 1/2 neutral \$4.63/ft
- 4/0, 220 mils, Al, EPR, full neutral Special Order
- 350, 220 mils, Al, EPR, 1/2 neutral \$6.04/ft

* EPR: Ethylene Propylene Rubber (Type of Synthetic Elastomer)
 * 1/2 Neutral & Full Neutral: Different carrying current



Figure 18 Conduit pipeline

Conduit Pipe:

- Sch 40 PVC \$1.15/ft
- Sch 13.5 HDPE Special Order